

CLIMATE-SPECIFIC MODELING AND ANALYSIS FOR BEST-PRACTICE INDIAN OFFICE BUILDINGS

Baptiste Ravache¹, Reshma Singh¹, Spencer M. Dutton¹

¹Building Technology and Urban Systems, LBNL, Berkeley, USA

ABSTRACT

This paper describes the methodology and results of building energy modeling to validate and quantify the energy savings from conservation measures in medium-sized office buildings in four different climate zones in India. We present the different energy measures and their expected and simulated performances and discuss the results and the influence of climate.

INTRODUCTION

Total primary energy demand in India in 2009 represented 5.5% of world energy demand and was predicted to increase by 8.6% by 2035 (Ahn & Graczyk, 2012). In addition to an exponential rise in energy demand, India already faces several energy challenges. These include: low grid availability, quality, and reliability (Pargal & Banerjee, 2014); significant energy imports (Yadav, 2014); and entrenched use of non-renewable, fossil-fuel sources (Ministry of Power - Government of India, 2013).

In India, the building sector is currently the second-largest energy consumer (29% of total energy demand) and is growing rapidly by 8% annually (Ahn & Graczyk, 2012). Although the building sector represents less than one-third of the total energy consumed in India, the savings potential is significant. India's Energy Conservation Building Code (ECBC) currently provides non-compulsory guidance. Simulation models indicate that "ECBC-compliant buildings can use 40 to 60% less energy than conventional buildings" (Ministry of Power - Government of India, 2007).

Simple improvements in building design and systems could increase energy efficiency, which would be an important step forward in addressing India's energy challenges.

Preceding work (Singh, Sartor, & Ghatikar, 2013) focused on identifying features of existing "best in class" Indian office buildings and listing measures of expected energy savings compared to energy use in conventional buildings. Although the case studies of pragmatic solutions and realistic benchmarks in that previous study are valuable, they cannot be used to differentiate the impact of individual energy measures.

As an alternative to collecting measured data, we use building energy simulation (BES) to model the impact of incremental energy-conservation measures. This allows us to evaluate the impact of individual measures on energy consumption and occupant comfort. BES can also fill gaps in measured building performance data, for example when the savings generated by a particular solution have not been measured in all of India's climate zones.

Such simulation studies have been performed in other geographical areas with climates similar to India's, such as Saudi Arabia (Iqbal & Al-Homoud, 2006) and sub-tropical Australia (Rahman, Rasul & Khan, 2010). Both of these studies used a real building to calibrate their models before simulating the potential savings from different energy conservative measures. In India, Manu et. al (2011), Dhaka et. al (2012), and Tulsyan et. al (2012) compared the performance of a conventional Indian building to an ECBC-compliant building but did not investigate further improvements to buildings.

In this work, we propose energy conservation measures that go beyond code compliance and that are rarely investigated in simulation work, such as radiant cooling, night flush, and mixed-mode ventilation. Unlike other studies, this study uses a generic medium-size office building in four different climate zones, to get more translatable results than those obtained using buildings that have specific uses, designs and external environments. The energy conservation measures might be applied in practice differently from the way they are modeled, or in buildings with different uses or designs. However, the goal of this study is not to predict exact savings but to identify solutions that have significant impact in the Indian context and to gain an understanding of the relative energy savings from these solutions. This, in turn, will inform future energy-efficient building guidelines.

METHODOLOGY

This research is conducted in two phases. In the first phase, we create two baseline models: business as usual (BAU) and ECBC-compliant. In the second phase, we use these two baseline models to analyze the impact on occupant comfort and energy consumption of incrementally implementing carefully selected, state-of-the-art design and

efficiency improvements that have been applied in existing energy-efficient buildings in India.

The strategies are added one by one, cumulatively, to create a best-practice building. The order in which the strategies are implemented prioritizes reducing loads before implementing solutions to reduce the energy cost of meeting those loads. The strategies modeled are:

- Optimizing building envelope orientation and fenestration to reduce external loads while maintaining significant daylighting
 - Reducing electric lighting and plug loads
 - Using night flushing and natural ventilation when available to promote “free” cooling
 - Using high-performance heating, ventilation, and air-conditioning (HVAC) system architecture that decouples ventilation and cooling. In analyzing this efficiency measure, we study compare the savings from radiant ceiling and variable-refrigerant flow (VRF) systems.

Simulation program

We used EnergyPlus 7.2 for modeling. EnergyPlus is a recognized whole-building energy-simulation program used worldwide, with more than 85,000 copies downloaded since it was first released in April 2001. The program includes various models for energy-flow transfer and HVAC systems. Although the validity of the whole-building models generated by EnergyPlus is a subject of discussion (Neto & Fiorelli, 2008) (Ko & No, 2015), this work covers only subsets of the tool’s functionality that have been previously validated (Olsen & Chen, 2002), (Sunman, Marston, & Baumann, 2013).

Model input parameters

We distinguish three types of input parameters in our model:

- Parameters specific to the building, such as occupancy, geometry, or envelope materials
- Parameters specific to the performance of building systems, such as HVAC equipment size or the heating or cooling setpoints
- Established parameters, such as the properties of the building materials used

We chose parameters specific to the building by consulting experts on Indian buildings, with the objective of developing a model of a typical medium-sized Indian office building.

We chose and tuned the parameters related to systems performance to optimize occupant comfort. Real systems might work with different, not ideal parameters, but a fixed comfort level in the model’s output leaves energy consumption as the only comparison value. This reduces the variability in modeled HVAC behavior and simplifies the analysis of the results.

The established parameters are taken from conventional building libraries, specifically the

medium-sized office building models distributed by the U.S. Department of Energy (DOE) (Deru et al., 2011).

Climate zone

India’s climate is typically divided into five zones that exhibit different temperatures, humidity, and solar irradiation. The five zones are designated as follows:

- “Hot and dry” climate in the Northwest region
- “Warm and humid” climate along the Indian Ocean coast
- “Composite” climate in the center, inland of the country
- “Temperate” climate around Bangalore
- “Cold” climate in the north and other elevated areas

This study focuses primarily on reducing cooling loads, which dominate the energy demand in India’s buildings. Therefore, we do not include the cold climate zone, which hosts only a small part of the country’s building stock. For the four other climate zones, we use weather data provided by India’s Department of Energy for the following cities:

- Jaipur, Rajasthan, for the “Hot and Dry” climate
- Mumbai, Maharashtra, for the “Warm and Humid” climate
- New Delhi, Delhi, for the “Composite” climate
- Bangalore, Karnataka, for the “Temperate” climate

Outputs

All of the models are simulated for an entire year. The three main types of outputs are:

- Comfort level
- Heat gains
- Energy consumption

Results for these three outputs are calculated as hourly averages at the zone and whole-building levels. The comfort-level assessment uses either the Fanger model (Fanger, 1967) for fully conditioned zones or the Brager model (De Dear & Brager, 2002) for naturally ventilated zones. Because the models are optimized to meet comfort requirements in every building zone at any time, this output is used mainly for validation. Nonetheless, in some of the early, energy-intensive design options simulated, it is not possible to meet our comfort target.

We analyze heat gains, both external and internal, to identify those that could be reduced to decrease the cooling load.

Energy consumption is the final metric used to assess building performance. When occupant comfort is maintained, energy use is used to characterize the building’s operation. We investigate five categories

of end uses: heating, cooling, ventilation, lighting, and plug loads.

MODELS

This study uses 44 optimized models corresponding to one “typical” baseline building, one code-compliant (ECBC) baseline building, and nine independent best-practices energy-conservation measures in four different climate zones.

The models for a given building in different climate zones are built using the same EnergyPlus objects but different input parameters, typically for wall composition, window properties, and HVAC equipment size with variations for code compliance (when applicable) or maintaining occupant comfort. Occupancy, geometry, and building use remain unchanged from one climate zone to another.

Baseline models

The baseline models represent a four-story, medium-size office building with four perimeters and one core zone per floor. The building dimensions are:

- North and south façade length: 50m each
- East and west façade length: 33m each
- Floor-to-floor height: 3.95m
- Ceiling height: 2.74m
- Perimeter zone depth: 6m

This generic geometry is based on the DOE reference model for medium-sized office building (Deru et al., 2011); other parameters of the model building represent common practice for new office buildings in India.

The typical building structure in the model has brick walls and concrete slabs, with a U-value of 2.18 $W \cdot m^{-2} \cdot K^{-1}$. Windows make up 80% of the envelope and are composed of single glazing modules with a low solar heat gain coefficient: U-value of 5.62 $W \cdot m^{-2} \cdot K^{-1}$ and Solar Heat Gain Coefficient (SHGC) of 48%. The building is a high-occupant-density, single-shift office with the following parameters:

- Lighting and plug-load power density are 15 watts per square meter (W/m^2) and 10.8 W/m^2 respectively.
- Occupant density is 10 m^2 /person.
- Occupancy starts at 7am and ends at 11pm on weekdays, with full occupancy between 9am and 6pm.

The HVAC system is a central air-handling unit (AHU) that provides air to all zones. The AHU includes an economizer, a supply and return fan, and a water-based cooling coil associated with a chiller and cooling tower. In each zone – one core and four perimeter zones per floor – a variable-air-volume (VAV) box controls the inflow and provides potential reheat. The chiller has a coefficient of performance (COP) of 5.8, representing the minimum requirement for centrifugal chillers that dominate the Indian market for high-capacity chillers (PACE-D Technical

Assistance Program, 2014). Most Indian buildings are not equipped with heating equipment, but analysis of our simulation results shows that a small heater is required to maintain optimal comfort on certain days in the typical and code-compliant buildings.

The code-compliant baseline building is identical to the typical building with some parameters updated to conform to code: walls are insulated (U-value of 0.44 $W \cdot m^{-2} \cdot K^{-1}$, window-to-wall ratio is reduced to 50%, and windows are double paned (U-value of 3.30 $W \cdot m^{-2} \cdot K^{-1}$ and SHGC of 22%) with shading. Lighting power density is reduced to 10.8 W/m^2 .

Energy-conservation measure models

We studied nine different energy-conservation measures that were added incrementally to previous model iterations except when new measures are not compatible with previous ones. Figure 1 shows the measures studied. Blocks that are grouped together share the same purpose:

1. Reducing external gains
2. Reducing internal gains
3. Promoting external losses
4. Decoupling cooling and ventilation

The arrows show how preceding modules are used in subsequent measures.




Figure 1 Energy-Conservation Measures




Figure 2 Energy consumption per end use for the baseline models

RESULTS

Baseline

The typical (or BAU) and code-compliant (ECBC) buildings are simulated for a whole year using the weather data from four different climate zones: hot and dry (Jaipur), warm and humid (Mumbai), composite (New Delhi), and temperate (Bangalore). Figure 2 shows the outputs.

Despite the diverse outdoor conditions of the four climate zones, the overall energy performance index (EPI), given by the energy consumption per square meter, remains similar for all cities. For a given building, only the cooling and ventilation end uses change from one location to another. The lighting and plug loads are independent of the climate. The fan consumption is greater in hotter climates despite ventilation requirements being the same for a given occupancy. We find that this is because, in all of these models, the cooling loads are met exclusively by the air system.

Table 1
EPI [kWh/m²] for Indian office building from data collection and simulation work

Data Collection (Best-Practice Guide)		250	150
Simulation	Bangalore	219	105
	Jaipur	253	121
	Mumbai	230	123
	New Delhi	241	119

The savings resulting from increasing efficiency from the BAU to the ECBC case come solely from a reduction in the energy use associated with air conditioning (labeled “cooling” and “fans” in Figure 2). The savings in the cooling demand result in part from use of shading, which reduces heat gain from the windows by 75%, and in part from a reduction in the window-to-wall ratio and solar heat gain coefficients. Cooling demand reductions result from

an almost 100% reduction in heat gains from the walls, achieved by the addition of wall insulation.

The EPI results in Table 1 are congruent with the first version of the Best Practice Guide, which was developed based on measured data collected from actual buildings. In addition, the 47% to 52% reduction in EPI in code-compliant buildings compared to typical buildings is consistent with the conclusion of the ECBC User Guide.

Reducing external gains

The first measures we implement to save energy in our models are related to the building’s orientation and fenestration.

Although the south façade makes the largest contribution to total solar energy received, buildings should be oriented such that the north and south façades are the longest and only façades with glazing. In the summer, when cooling demand is greatest, the west and east façades receive more solar energy than the south. Direct solar radiation from the west and east has a low solar elevation, making it more difficult to shade whereas overhangs are sufficient to block the higher-elevation sunlight from the south.

When we optimize the aspect ratio of the building from 1.5 to 4 so that the south and north façades dominate and reduce the overall window-to-wall ratio by 30%, we see a 40% decrease in annual solar heat gains. Although solar heat gains are not the dominant component of the cooling load, this reduction in solar heat gain translates to a 12% decrease in cooling and fan energy consumption. It should also be noted that solar heat gains are not always detrimental to energy use; they provide beneficial heating during occasional cold days.

When we add adequate shading to the windows with consideration of the solar trajectory at each location (Parekh & Dadia, 2014), the cooling and fan consumption drops to 16% of the consumption in a code-compliant equivalent building. The interior lights are controlled on a schedule independent of exterior conditions, so lighting consumption did not change. When we include the cooling and fan reduction in the whole-building energy consumption, the resulting savings increase from 7% to 10%.

Reducing internal gains

The building’s electrical equipment has a double effect on the energy consumption: it directly consumes electricity, and it uses this energy to create heat, which increases the cooling load and therefore the HVAC system energy consumption. In the previous iteration of the simulation with optimized envelope performance, the electrical equipment (lighting and plug loads) consumes 55% of the total energy used and accounts for 70% of the total heat gain.

Improved management of office electrical equipment and lighting, including turning off unused equipment and unneeded lights, can drastically reduce energy use.

Simulating improved electricity load management based on use or occupant movement would require a complex behavioral model. To simplify this simulation, we reduce the power density of lighting and plug loads based on input from interviewed experts and best-in-class buildings data. In parallel, we add daylight sensors that dim the artificial lighting when natural sunlight is available, and maintain illuminance to 300 lux. The use of increased daylighting is promoted by the optimized envelope in the previous model.

The results confirm that reducing lighting power density by 50% and plug load power by 25% reduces annual lighting and plug load energy consumption by 50% and 25%, respectively. Daylighting sensors and controls reduce lighting electricity consumption further, to 20% of its initial value.

The effect of lighting and plug-load reduction on cooling loads is substantial: total annual heat gains (both external and internal) are reduced by 36%, which reduces HVAC demand by 33%. Figure 3 shows how the measures reduce heat gains from lighting and electrical equipment (averaged for all four climates).

Overall, adoption of simple, effective energy management reduces building energy consumption by 38% to 48%. These ideal savings can only be achieved if the plug-load and lighting reduction strategies are carried out by every building occupant.




Figure 3 Annual heat gains by source, before and after load management

Promoting external losses

After integrating building envelope and internal gains measures in the two model iterations described above, we find that cooling and ventilation loads still represent about 40% of annual consumption. Another simple way to reduce cooling energy consumption is to use outside fresh air when available. We apply two different measures based on that premise: night flushing and changeover mixed-mode ventilation.

Night flushing which is used to actively (with fans) or passively (by motorized or operable windows) ventilate the building at night when the outside air is colder than the inside air. Although cooling and ventilation demand is lowest at night, this process can help quickly cool the building mass below the occupancy comfort setpoint; that cooling affects building temperature throughout the following day, reducing the cooling requirements.

The results of night flushing vary depending on outdoor conditions. In the hottest climate zones like Jaipur or New Delhi, night flushing produces few to no savings. Only the temperate climate shows significant savings from night flushing, a 24% reduction in cooling and fan consumption, as a result of colder night in summer.

The significant savings obtained in Bangalore would only be achievable in a building with a heavy structure, as is the case in the model building. The model building’s walls and floors are made of high-inertia materials such as brick and concrete, with a thermal capacity ranging from 100 kJ·m⁻²·K⁻¹ for internal floors to 400 kJ·m⁻²·K⁻¹ for external walls. When night flushing is used in a building with a light structure, such as a steel-framed building with a capacity ranging from 10 to 40 kJ·m⁻²·K⁻¹, fan and cooling energy savings dropped to 7% in the temperate climate.

The second method of reducing cooling and loads is changeover mixed-mode ventilation, which is an extension of night flushing applied during the daytime. In this approach, if the outside air temperature is lower than the inside air temperature, and the inside air temperature is higher than the minimum requirements for comfort, the mechanical ventilation is shut down, and windows are opened. Mechanical cooling is turned back on when the comfort conditions cannot be meet with fresh air.

Occupants report that naturally ventilated spaces are more comfortable than those that are mechanically ventilated (Brager, Ring, & Powell, 2000). Therefore, for the models integrating mixed-mode spaces, we introduce a different comfort definition using the Brager model (De Dear & Brager, 2002). Brager has shown that, in naturally ventilated spaces, comfort can be closely connected to a weighted average of the exterior temperature over the preceding weeks. Other studies have shown that this observation can be extended to occupants transitioning from naturally to mechanically ventilated spaces.

Although we might expect the savings from mixed-mode ventilation to be similar to those from night flushing, the above redefinition of comfort allows greater flexibility and so delivers greater savings in climates with low seasonal temperature variability than in climates with a high daily temperature variability. In other words, in climates where it is hot all year round, people typically have higher heat tolerance and find hotter environments more comfortable than is the case for people in more variable climates.

The lowest seasonal variability is in the temperate and warm and humid climates of Bangalore and Mumbai. In these climates, simulation shows that the integration of mixed-mode zones in more than 82% of the conditioned area reduces cooling demand by 43% and 41%, respectively.

The composite and hot and dry climates of New Delhi and Jaipur show lesser but still important savings from incorporation of mixed-mode ventilation, with a cooling demand reduction of 23%.




Figure 4 Comparison of cooling demand for fully conditioned and mixed-mode buildings in Mumbai

Figure 4 shows that cooling energy savings come mainly from modifying the temperature setpoint definition (the difference between the black continuous line and the dotted grey line), and the “free cooling” from natural ventilation operation has less impact on savings (the difference between the dotted grey line and the continuous one). Therefore, we conclude that the comfort definition is the dominant contributing factor to the energy savings. However, these results are highly dependant on the validity of the comfort model used.

Decoupling cooling and ventilation

VRF HVAC technology uses a refrigerant loop for space cooling. The loop is composed of an outdoor unit with condenser and cooling towers for heat removal, and one or multiple evaporators in the different conditioned spaces to cool down the indoor air. The benefit of this type of system is that it

decentralizes air cooling and decouples it from the ventilation. This allows a considerable reduction in ventilation equipment size compared to conventional systems. With a centralized, conventional air-conditioning system, air-supply temperature is determined by the cooling demand of one master zone. If the cooling demand for zones on the same loop varies significantly, a centralized system won't be able to satisfy all demands and will cause over-ventilation, overcooling or unnecessary reheating in one or multiple zones.

VRF systems eliminate those problems and provide the required cooling for each zone. Moreover, in comparison to other decoupling solutions such as radiant cooling, VRF systems are assumed (Thornton & Wagner, 2012) to have a lower construction and operating cost with a higher degree of decentralized control. This type of system can be a good alternative for retrofits (slab radiant systems are more difficult to adapt to an existing design).

When we replace conventional VAV space-cooling systems with VRF systems in our simulations, and replaced the COP from 5.8 to 4 to account for a less efficient system (PACE-D Technical Assistance Program, 2014), the results confirm our expectations that cooling and ventilation consumption are considerably reduced in every climate. The reduction is greatest in climates that have significant cooling needs; the higher the cooling demand, the greater the savings, as shown in Figure 5. Savings in cooling equipment energy use range from 20% to 26%, and savings in fan energy use range from 38% to 51%.




Figure 5 Cooling and fan energy consumption in VAV and VRF systems

High-temperature cooling

A second alternative for decoupling cooling and ventilation is to use hydronic, high-temperature cooling, such as radiant panel systems. Radiant panel cooling can be expensive and is not suitable for all retrofit applications. It also requires large

installations that don't fit every building design. However, radiant panel cooling has one key advantage over VRF: because of the large surface area of a radiant panel system, a higher temperature can be used for radiant cooling than can be used in a VRF system. When water is used as the thermal fluid, the volume transported is less than required in a conventional air system, which saves fluid-transport energy use. Occupants also report that radiant cooling is more comfortable and gentler than other systems (Feustel & Stetiu, 1995).

We updated the cooling equipment coefficient of performance (COP) in our models from 4 to 5.8 to account for the better fluid medium and higher supply temperature in the radiant panel system.

Results show that when fan use is limited to providing minimum ventilation in occupied spaces, fan energy consumption is reduced to 4kWh/m². Cooling consumption under the radiant panel scenario is also lower than in the VRF scenario, with savings ranging from 33% to 46%, mainly because of the radiant system's better COP. We should note that, although the modeled radiant panels are controlled to prevent condensation, water vapor flows are not fully integrated in the models. Actual performance might be reduced in humid climates.

Best HVAC suite

Finally, we maximize the energy-use reduction in our scenarios by incorporating the best-in-class HVAC equipment for a medium-sized office building in India. In this model, we combine a radiant system with naturally ventilated spaces and high-efficiency magnetic bearing chillers (COP 7).

The result is buildings with minimal cooling and fan energy consumption. The majority of total building energy demand comes from lighting, plug loads, and service hot water (representing from 60% to 75% of total energy, depending on climate).

Table 2

EPI per climate and building performance for models that include best-in-class HVAC equipment

EPI [kWh/m ²]	Typical	ECBC	Best
Bangalore Temperate	219	105	45
Jaipur Hot and Dry	253	121	53
Mumbai Warm and Humid	230	123	53
New Delhi Composite	241	119	53

Table 2 shows total energy consumption for baseline and best models per climate. The best models show a total energy savings of 77% to 79% compared to typical buildings, and 55% to 57% compared to code-compliant buildings.

CONCLUSION

In this study, we simulate the cumulative addition of a series of energy-conservation measures to a typical Indian medium-sized office building to determine the efficiency impact of each measure.

In the real world, a building's energy consumption depends heavily on the building's use and the external environment in which the building operates; therefore, it is difficult to compare the performances and effect of efficiency improvements in two different buildings, particularly when they are in two different climates. Building simulation allows us to create the same environment for every modeling run and understand the effect of each improvement modeled based on an apples-to-apples comparison.

Our results provide high-level, climate-specific guidance about which energy-saving strategies are likely to have a greater chance of success and which ones probably will not be effective in particular climate zones in India.

- In a temperate climate like Bangalore (or Pune), it may not be worth investing in radiant panels because a similar level of energy benefits can be achieved through mixed-mode operations. A VRF system is similarly effective in this climate zone.
- The simulations for hot dry weather such as Jaipur (or Ahmedabad) show that a radiant system is effective, providing 25% savings over an optimized VAV system with a good envelope and reduced lighting power density and plug loads.
- In hot and humid areas such as Mumbai (or Chennai), an optimal modeled performance can be attained using a radiant system. Mixed-mode and VRF systems also save significant energy.
- In a composite climate such as New Delhi (or Chandigarh or Hyderabad), a radiant model provided optimal savings of 24% over an optimized VAV system with a good envelope and reduced lighting power density and plug loads.

This study also provides insight into the theoretical limits of the energy-savings potential of energy-efficiency strategies. We found that, through a series of improvements, it is possible to reduce a building's EPI by 75% compared to a building with typical design, and by more than 50% compared to a building that meets current energy code. This shows that buildings in India can strive toward more aggressive targets than those outlined in the ECBC.

The simulation data in this study are consistent with benchmarked energy-performance data collected from various office buildings in India (Singh, Sartor, & Ghatikar, 2013). These data on the effectiveness of various energy-efficiency strategies can be used to develop a robust set of target metrics for office buildings.

Future work will focus on evolving from climate-specific to building-specific studies, developing an interactive tool for building practitioners.

ACKNOWLEDGMENT

This work was supported by the Assistant Secretary of Energy Efficiency and Renewable Energy, International Program under the U.S. Department of Energy under Contract No. DE-AC02-05CH11231

The authors would like to thank the following for their insightful review and encouragement:

Ashok Lall of Ashok B Lall Associates; Rajan Rawal of Centre for Environmental Planning and Technology, Ahmedabad; Jagadeesh Taluri of Metro Valley Business Park Pvt. Ltd; Milind Rane of IIT Mumbai; Gian Chand Modgil of Sterling India Limited; Guruprakash Sastry, and Punit Desai from the Infosys Green Initiatives Team; and Gail Brager from Center for Built Environment at University of California at Berkeley.

REFERENCES

- Ahn, S.J., Graczyk, D. 2012. Understanding Energy Challenges in India. International Energy Agency. https://www.iea.org/publications/freepublications/publication/India_study_FINAL_WEB.pdf
- Brager, G., Ring, E., Powell, K. 2000. Mixed-mode ventilation: HVAC meets Mother Nature. *Engineered Systems*, May: 60-70.
- De Dear, R. J., Brager, G. S. 2002. Thermal comfort in naturally ventilated buildings: revisions to ASHRAE Standard 55. *Energy and Buildings* 34(6): 549-561.
- Deru, M., Field, K., Studer, D., Benne, K., Griffith, B. 2011. U.S. Department of Energy commercial reference building models of the national building stock. University of Nevada, Las Vegas.
- Dhaka, S., Mathur, J., Garg, V. 2012. Combined effect of energy efficiency measures and thermal adaptation on air conditioned building in warm climatic conditions of India. *Energy and Buildings* 55: 351-360.
- Fanger, P. 1967. Calculation of thermal comfort: introduction of a basic comfort equation. *ASHRAE Trans.* 73(2): III.4.1-III.4.20.
- Feustel, H. E., Stetiu, C. 1995. Hydronic radiant cooling - preliminary assessment. *Energy and Buildings* 22(3): 193-205.
- Iqbal, I., Al-Homoud, M. S. 2006. Parametric analysis of alternative energy conservation measures in an office building in hot and humid climate. *Building and Environment* 42(5): 2166-2177.
- Ko, Y.-S., No, S. T. 2015. A Study on Comparison of Building Energy Simulation and Measurement Results for a City Hall. Scientific Research Academic Publisher. <http://www.scirp.org/Journal/PaperInformation.aspx?PaperID=53986#.VYNT2fiVhBd>
- Manu, S., Wong, J., Rawal, R., Thomas, P.C., Kumar, S., Deshmukh, A. 2011. An initial parametric evaluation of the impact of the energy conservation building code of India on commercial building sector. Proceedings of BS2011. Sydney, Australia: International Building Performance Simulation Association.
- Ministry of Power - Government of India. 2007. Energy Conservation Building Code.
- Ministry of Power - Government of India. 2013. Power Sector at a Glance "All India." <http://powermin.nic.in/power-sector-glance-all-india>. Accessed on 30-09-2013.
- Neto, A. H., Fiorelli, F. A. 2008. Comparison between detailed model simulation and artificial neural network for forecasting building energy consumption. *Energy and Buildings* 40(12): 2169-2176.
- Olsen, E. L., Chen, Q. 2002. Energy consumption and comfort analysis for different low-energy cooling systems in a mild climate. *Energy and Buildings* 35(6): 560-571.
- PACE-D Technical Assistance Program. 2014. HVAC Market Assessment and Transformation Approach for India.
- Parekh, H., Dadia, D. 2014. Climate Based Guidelines for Energy Efficient Building Facade for 5 Climates in India. Master's thesis. Carnegie Mellon University. Unpublished.
- Pargal, S., Banerjee, S. G. 2014. More Power to India - The Challenge of Electricity Distribution. Washington D.C.: The World Bank.
- Singh, R., Sartor, D., Ghatikar, G. 2013. Best Practices Guide For High-Performance Indian Office Buildings. Berkeley CA: Lawrence Berkeley National Laboratory.
- Rahman, M. M., Rasul, M. G., Khan, M. M. K. 2010. Energy conservation measures in an institutional building in sub-tropical climate in Australia. *Applied Energy* 87(10): 2994-3004
- Sunman, R., Marston, A., Baumann, O. 2013. Analysis of chilled ceiling performance to control temperature in a data control center using Energyplus: A case study. Proceedings of BS2013. Chambéry, France: International Building Performance Simulation Association.
- Thornton, B., Wagner, A. 2012. Variable Refrigerant Flow Systems. Seattle WA: Pacific Northwest National Laboratory. http://www.gsa.gov/portal/mediaId/197399/fileName/GPG_Variable_Refrigerant_Flow_12-2012.action
- Tulsyan, A., Dhaka, S., Mathur, J., Yadav, J. V. 2013. Potential of energy savings through implementation of Energy Conservation Building Code in Jaipur city, India. *Energy and Buildings* 58: 123-130.
- Yadav, P. K. 2014. Problems and Obstacles to Market Building in the Indian Energy Sector. in *The Politics of Marketising Asia*, eds. T. Carroll, D. S. Jarvis. London: Palgrave Macmillan, pp. 252-268.